

Certificate of Compliance

Monitor Assemblies

This certificate is issued for the following equipment:

**Style 3528 Omega XP Monitors
Rated to 1250 gpm (4730 Lpm)
Maximum operating pressure of 200 psi (13.8 bar)
Brass construction**

Manufactured by:

**Akron Brass Company
343 Venture Blvd.
P.O. Box 86
Wooster, Ohio 44691**

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 1421 (June 2007)

Project Identifier: 3030786

Date of Approval: May 29, 2008



Richard B. Dunne, Group Manager
FM Approvals – Hydraulics Group

May 29, 2008
Date



Member of the FM Global Group